



Title	Impacts of large amounts of wind power on design and operation of power systems, results of IEA collaboration
Authors(s)	Holttinen, Hannele, Meibom, Peter, Orths, Antje, et al.
Publication date	2011-03-14
Publication information	Holttinen, Hannele, Peter Meibom, Antje Orths, and et al. "Impacts of Large Amounts of Wind Power on Design and Operation of Power Systems, Results of IEA Collaboration." Wiley Blackwell (John Wiley & Sons), March 14, 2011. https://doi.org/10.1002/we.410 .
Publisher	Wiley Blackwell (John Wiley & Sons)
Item record/more information	http://hdl.handle.net/10197/4750
Publisher's statement	This is the Author's version of the following article: Hannele Holttinen, Peter Meibom, Antje Orths, Bernhard Lange, Mark O'Malley, John Olav Tande, Ana Estanqueiro, Emilio Gomez, Lennart Söder, Goran Strbac, J Charles Smith, & Frans van Hulle (2011) "Impacts of large amounts of wind power on design and operation of power systems, results of IEA collaboration" Wind Energy, 14 : 179-192 which has been published in final form at http://dx.doi.org/10.1002/we.410 .
Publisher's version (DOI)	10.1002/we.410

Downloaded 2026-05-01 23:49:52

The UCD community has made this article openly available. Please share how this access benefits you. Your story matters! (@ucd_oa)



© Some rights reserved. For more information

Impacts of large amounts of wind power on design and operation of power systems, results of IEA collaboration

Hannele Holttinen¹⁾, Peter Meibom²⁾, Antje Orths³⁾, Bernhard Lange⁴⁾, Mark O'Malley⁵⁾, John Olav Tande⁶⁾, Ana Estanqueiro⁷⁾, Emilio Gomez⁸⁾, Lennart Söder⁹⁾, Goran Strbac¹⁰⁾, J Charles Smith¹¹⁾, Frans van Hulle¹²⁾

¹⁾ VTT, Finland, e-mail hannele.holttinen@vtt.fi ²⁾ Risø DTU, Denmark; ³⁾ Energinet.dk, Denmark; ⁴⁾ ISET, Germany; ⁵⁾ University College Dublin, Ireland; ⁶⁾ SINTEF, Norway; ⁷⁾ INETI, Portugal; ⁸⁾ University Castilla la Mancha, Spain; ⁹⁾ KTH, Sweden; ¹⁰⁾ DG&SEE, UK; ¹¹⁾ UWIG, USA; ¹²⁾ EWEA

Abstract-- There are dozens of studies made and ongoing related to wind integration. However, the results are not easy to compare. IEA WIND R&D Task 25 on "Design and Operation of Power Systems with Large Amounts of Wind Power" collects and shares information on wind generation impacts on power systems, with analyses and guidelines on methodologies. In the state-of-the-art report (October, 2007), and the final report of the 3 years period (July, 2009) the most relevant wind power grid integration studies have been analysed especially regarding methodologies and input data. Several issues that impact on the amount of wind power that can be integrated have been identified. Large balancing areas and aggregation benefits of wide areas help in reducing the variability and forecast errors of wind power as well as help in pooling more cost effective balancing resources. System operation and functioning electricity markets at less than day-ahead time scales help reduce forecast errors of wind power. Transmission is the key to aggregation benefits, electricity markets and larger balancing areas. Best practices in wind integration studies are described. There is also benefit when adding wind power to power systems: it reduces the total operating costs and emissions as wind replaces fossil fuels and this should be highlighted more in future studies.

keywords—wind integration, grid integration, balancing, wind power forecast

1 Introduction

Adding wind power will bring about a variable and only partly predictable source of power generation to a power system that has to balance generation and varying demand at all times.

1.1 Power system impacts of wind power

Wind power has impacts on power system operational security, reliability and efficiency. The studies address different impacts, and the different time scales involved usually mean different models (and data) used in impact studies. The case studies for the system wide impacts have been divided to three focus areas: Balancing, Adequacy of power and Grid (Fig 1). In this international collaboration (IEA WIND Task 25; www.ieawind.org/AnnexXXV.html), more system related issues are addressed, as opposed to local issues of grid connection like power quality. Primary reserve is here denoted for reserves activated in seconds (system-wide frequency activated reserve; regulation; automatically activated reserve of the balancing zones). Secondary reserve here denoted for reserves activated in 10...15 minutes (minute reserve; load following reserve; manually activated).




Fig. 1. Impacts of wind power on power systems, displayed by time and spatial scales relevant for the studies.

High penetration of wind power has impacts that have to be managed through proper wind power plant interconnection, integration of the generation, transmission planning, and system and market operations. The final report of Task 25 first term presents a summary of selected, recently concluded studies of wind integration impacts from participating countries [1]. The case studies summarized are compared, although this is not an easy task due to different methodology and data used, as well as different assumptions on the interconnection capacity available.

There are already several power systems and control areas coping with large amounts of wind power [2]. The experience from Denmark, Spain, Portugal and Ireland that have integrated 13-20 % of wind energy (percentage of gross demand as energy) show that wind power production will only have to be curtailed (regulated) at some rare instances, and that TSOs need on-line information of both the production and demand levels as well as respective forecasts in their control rooms. Spain and Portugal have launched centers for distributed energy that convey data to TSOs and even can react to control needs. Suitable grid codes help to further increase the penetration level. All the countries with experience on higher penetrations of wind, and also several others, have implemented fault-ride-through requirements for wind power plants in order to keep a certain level of security of supply.

1.2 Integration cost of wind power

Many studies assess impacts of wind power and some studies also estimate integration costs arising from the impacts. Integration cost is the extra investment and operational cost of the non-wind part of the power system when wind power is integrated.

Integration cost can be divided into different components arising from the increase in the operational balancing cost and grid reinforcement cost. It is important to note whether a market cost has been estimated or the results refer to technical costs for the power system. A “market cost” includes transfer of money from one actor to another actor, while “technical costs” implies a cost for the whole system.

Most studies so far have concentrated on the technical costs of integrating wind into the power system while also cost-benefit analysis work is emerging. The benefit when adding wind power to power systems is reducing the total operating costs and emissions as wind replaces fossil fuels. Integration costs of wind power need to be compared to something, like the production costs or market value of wind power, or integration cost of other production forms. A fair comparison between power systems with differing amounts of wind

power, should in principle have systems with the same reliability but also same CO₂ emissions or at least take the CO₂ emission costs into account. The value of the capacity credit of wind power can also be stated.

1.3 Defining wind penetration level

The penetration of wind power can be expressed by various measures. Often either energy or capacity metrics are used: wind power production as a percentage of gross demand (energy) and wind power capacity as a percentage of peak load (capacity). These measures neglects however the presence of interconnecting capacity with neighbouring countries, though exactly the cross-border interconnections are many times the key to efficient power system operation. In particular for the case of high wind and minimum load, operational constraints may be alleviated through utilizing cross-boarder transmission capacity for export of (excess) generation. It is thus relevant also to express wind penetration level in terms of wind capacity in percentage of the sum of minimum load and cross-boarder capacity. The power systems and highest wind penetrations presented in the case studies are summarised in Fig 2. It can be seen that taking into account the limitations of interconnection capacity, the penetration levels of Ireland and UK are more challenging than for the other European countries. For a small part of an interconnected system, a wind integration study stating a high penetration level can also be misleading if the wind penetration in neighbouring areas is low and interconnection capacity plays a major part in integration.




Fig. 2. Comparison of the share of wind power in the power system (penetration levels) studied. For studies covering several countries, the aggregate penetration level has been calculated. Individual countries within the study cases can have significantly higher wind power penetration levels.

This paper summarises the results of several wind integration studies carried out within the IEA Wind Task 25 research project. In Section 2 the short term reserve requirements due to wind power are discussed, and Section 3 addresses the balancing costs related to wind power. In Section 4 other results to balancing are

presented, and Section 5 looks at costs of grid reinforcements due to wind power. The capacity value of wind power is discussed in Section 6, and recommendations for future wind integration studies are given in Section 7. Finally, Section 8 concludes and future work is discussed.

2 Increase in short term reserve requirements due to wind power

Wind generation may require system operators to carry additional operating reserves. From both the experience and results from studies performed, a significant challenge is the variability of wind power within 1–6 hrs. Inertial response, frequency control (time scale of seconds) and fast automatic balancing (time scales of seconds to minutes) are not crucial problems when integrating wind power into large systems at the present time, but can be a challenge for small systems or isolated medium (like Ireland) and will become more of a challenge for systems with high penetration in the future.

2.1 Methodology

The increase in short term reserve requirement is mostly estimated by statistical methods combining the variability or forecast errors of wind power with that of load and in some cases also power plant outages, and investigating the increase in the largest variations seen by the system [2]. Usually margins for “possible” extreme situations are kept, i.e. a very small loss of load probability is allowed in a balancing area, which is to be balanced system-wide. The term “possible” then normally includes a certain percentage of what in reality could happen. A straightforward method to define “possible” is the commonly used “N-1 criterion”, i.e., it is necessary to keep reserves for an outage of the largest production unit or interconnector, which could be a challenge during both import and export situations. This is a common dimensioning criteria for disturbance (contingency) reserve. In addition, some operational reserve is carried on top of that to cover variability and forecast errors, but there are no commonly used criteria to dimension this part of reserve. Some TSOs are beginning to use probabilistic approaches to define a suitable level of reserves.

It is of central importance to separate the need for flexibility in longer time scales of several hours to a day (power plants that can follow net load variation) from the need for reserves that can be activated in the seconds or minutes time scale (power plants that can follow unforecasted net load variations). To illustrate the need for flexibility, Fig. 3 shows the needed power increase divided into scheduled production and reserves.




Fig. 3. Flexibility in the power system to follow varying load and wind power production (the net load) consists of scheduled production and reserves.

The need for flexibility is not the same as need for reserves, since a part of the net load variation can be forecasted. Reserves mainly deal with forecast errors and the overall flexibility in scheduling deals also with the changes in output level for several hours and a day ahead.

2.2 Results from studies

The results presented in Fig. 4 for increase in reserve requirements due to wind power are from the following studies: Finland and Nordic [4]; Sweden [5]; Ireland [6]; UK [7]; Germany [8]; Minnesota 2006 [9] and California [10].

The estimated increase in short term reserve requirements in the studies has a large range: 1–15 % of installed wind power capacity at 10 % penetration (of gross demand) and 4–18 % of installed wind power capacity at 20 % penetration. Time scales used in the estimation explain much of the differences in results:

- If only hourly variability of wind is taken into account when estimating the increase in short term reserve requirement, the results are 0.5–4 % of installed wind capacity or less, with penetrations below 10 % of gross demand.
- When 4 hour forecast errors of wind power are taken into account, an increase in short term reserve requirement of 4–5 % of installed wind capacity has been reported, with penetration levels of 5–10 % of gross demand.




Fig. 4. Results for the increase in reserve requirement due to wind power. German Dena estimates are taking into account the day-ahead uncertainty (for up and down reserves separately) and UK the variability of wind 4 hours ahead. In Minnesota and California, day ahead uncertainty has been included in the estimate. For the others the effect of variations during the operating hour is considered. For Ireland and Sweden the 4 hour-ahead uncertainty has been evaluated separately.

The highest results in Fig. 4 are from a study where four hour variability of wind assuming that no wind power forecast is used, is combined with load forecast error. This results in 15 % reserve requirement at 10 % penetration and 18 % reserve requirement at 20 % penetration of gross demand [7]. The latest achievements in wind forecasting show a considerable improvement of predictions also in short time scales, so using updated forecasts would reduce this estimate. If day-ahead forecast errors are left to be balanced with the short term reserves, the increase in short term reserve requirement is nearly 10 % (two points for Germany reflect difference in up- and down-regulation requirements) [8]. In this German study, the reserve requirement is taken as the average impact of day-ahead forecast errors of wind power. The maximum values would result in an increase that is 15–20 % of installed wind capacity.

In most studies, reserve requirements for different time frames are summed up – for example, increase in regulating reserves + increase in load following reserves. There are some studies showing a larger increase in reserve requirement than shown here. The Swedish TSO published estimates for reserves that are 35–48

% of installed wind capacity. This is due to adding up several cases and time frames of reserves. However, the different time frames, for example one hour ahead and four hours ahead, are strongly overlapping. If one has enough flexibility for 4 hours, then this in general implies that during this period there is enough flexibility for 1 hour ahead. In this case there is no meaning in summing up these reserve requirements since they overlap significantly. Such additions are only valid when they contain reserve allocation in different generation units.

An important issue is that “increase in reserve requirements” does not necessarily mean need of new investments, as a matter of fact the experience so far from countries that have a lot of wind power shows that this is seldom the case. The amount of wind-caused reserves is at its highest when wind power is at a high production level. In these situations the other power stations are usually operated at a low level, i.e. they can act as reserves and increase the generation if wind power decreases. This means that flexibility and reserve keeping in a system with wind power are mainly issues of ramp rates and start-up times, and sometimes also a need of more capacity or different kind of generation units. Faster ramping and starting capacity may be needed, if the forecast errors are large enough that the slow units cannot follow. This must be considered when “increased reserve margins” are to be estimated.

3 Balancing cost

Wind power impacts on power system balancing can be seen in several time scales, from minutes to hours, up to the day-ahead time scale. General conclusions on increase in balancing requirement will depend on region size relevant for balancing, initial load variations and how distributed wind power is sited. Here also the operational routines of the power system are relevant – how often the forecasts of load and wind are updated, for example.

3.1 Methodology

To arrive at estimates for balancing cost, the operating reserve impact is one issue (increase in reserve requirement from statistical methods) and impact on efficiency of conventional power plants for day-ahead operation is another issue (simulations). For the simulations most results are based on comparing costs of system operation without wind and adding different amounts of wind. The costs of variability are also addressed by comparing simulations with flat wind energy to varying wind energy (for example in US Minnesota [9] and Greenet Nordic + Germany [12]).

It is important to pay attention to the representativeness of wind input data (how well does the wind data represent the geospread of the power system, how is wind power simulated, what time scale effects on variability and predictability have been taken into account) and also how the main set-up for the assessment or simulation is made (wind power replacing other production or capacity and to what extent is the power system operation optimised when wind power production is added). It is important to have the wind data synchronous with load data to capture the correlations. The level of detail of the simulation model (time resolution, level of detail in simulating conventional generation and transmission, pricing) and how the uncertainty in the wind plant output forecast is handled with respect to the load forecast uncertainty are also important.

The matrix developed in [12] has been further processed to form a check-list for the national studies that have used simulations [1]. The check-list can be used to find out whether the approach has been conservative or whether some important aspects have been omitted, producing either high or low estimates for the impacts. The most general finding comparing the study set-ups is the use of interconnection capacity – this is crucial when estimating the impacts of wind power.

3.2 Results from studies

The results presented in Fig. 5 for increase in balancing costs due to wind power are from the following studies: Finland and Nordic countries [4]; UK [14],[7]; Ireland [6]; Colorado [15]; Minnesota [16],[9]; California [17]; PacifiCorp [18]; Nordic countries and Germany [12].

From the cost estimates presented in the investigated studies it follows that at wind penetrations of up to 20 % of gross demand (energy), system operating cost increases arising from wind variability and uncertainty amounted to about 1–4 €/MWh of wind power produced (Fig. 5). This is 10 % or less of the wholesale value of the wind energy. The actual impact of adding wind generation in different balancing areas can vary depending on local factors. Important factors identified to reduce integration costs are aggregating wind plant output over large geographical regions, larger balancing areas, and utilizing shorter gate closure times with accurate forecast systems and sub-hourly schedule changes.

The highest estimates of reserve requirements from Germany and UK are not reflected in balancing costs, as from both studies it was concluded that this amount of reserve can be handled with the current conventional power plants. From UK, only the increased cost of operating existing reserves has been estimated.




Fig. 5 Results from estimates for the increase in balancing and operating costs due to wind power. The currency conversion used here is 1 € = 0.7 £ and 1 € = 1.3 US\$. For UK, 2007 study the average cost is presented here, the range in the last point for 20 % penetration level is from 2.6 to 4.7 €/MWh.

In addition to estimates, there is some experience from Denmark for the actual balancing costs for the existing wind power. For West Denmark, the balancing cost from the Nordic day-ahead market has been 1.4–2.6 €/MWh for a 24 % wind penetration (of gross demand). These numbers are quite in the middle of theoretically estimated results from studies depicted in Fig. 5. The balancing cost paid by the wind power producers is not the same as the increase in technical cost of balancing for that amount of wind power. However, the market costs from Denmark and Spain reflect the cost incurred to the system. In Denmark the cost is low compared to the penetration level, as the cost comes from the Nordic market where wind power penetration is still small.

The interconnection capacity to neighbouring systems is often significant. For the balancing costs, it is then essential to note in the study setup whether the interconnection capacity can be used for balancing purposes or not. A general conclusion is that if interconnection capacity is allowed to be used also for balancing purposes, then the balancing costs are lower compared to the case where they are not allowed to be used. The two points for Greenet Germany at the same wind penetration level reflect that balancing costs increase when neighbouring countries get more wind (the same applies for Greenet Denmark). For a small part of an interconnected system, a wind integration study stating a high penetration level can also be misleading if the wind penetration in neighbouring areas is low and interconnection capacity plays a major part in integration.

4 Other balancing related results

Not all case studies presented results quantified as MW of increase in reserve requirements or monetary values for increase in balancing costs.

In Denmark the TSO has estimated the impacts of increasing the wind penetration level from 20 % to 50 % (of gross demand) and concluded that further large scale integration of wind power calls for exploiting both, domestic flexibility and international power markets with measures on the market side, production side, transmission side and demand side ([19] and [20]).

For the Netherlands, the simulations show the benefit of international trade of electricity and postponing market gate closure for wind integration. Wind power worsens the business case for thermal generation, reducing CCGT during peak demand and base-load coal during low demand periods [21].

The Irish All Island Grid Study shows that going from 2 to 6 GW wind, the operational costs of the electricity system fall by €13/MWh when compared to the base case. Due to cost benefit approach in the study, the wind integration cost component was not published as such, only the results of the total system costs that show the decrease of the total operating cost due to wind power replacing fuels for conventional generation [22].

For New York, 10 % penetration of capacity, incremental regulation due to wind was found to be 36 MW. No additional spinning reserve was needed. Incremental intra-hour load following burden increased 1–2 MW / 5 min. Hourly ramp increased from 858 MW to 910 MW. All increased needs can be met by existing NY resources and market processes. System cost savings of \$335–\$455 million for assumed 2008 natural gas prices of \$6.50–\$6.80/MMBTU were found. Day-ahead unit-commitment forecast error σ increased from 700–800 MW to 859–950 MW. Total system variable cost savings increases from \$335 million to \$430 million when state of the art forecasting is considered in unit commitment (\$10.70/MWh of wind) [23].

4.1 Balancing cost from electricity markets

In Finland and Sweden, the balancing costs as payments for wind power producers have been estimated from the balancing market (Nordic Regulating market) prices to be 0.3–1.4 €/MWh depending on how distributed the wind power is and on the market price level for balancing ([24] and [25]). In Sweden, the use of 15 min operating reserves has been estimated to increase by 18–56 % of current amounts due to wind power forecast errors 1 or 4 hours ahead for 4000 MW wind power (8 % of gross demand) [26]. The increased cost of system imbalances of Finland due to future wind power prediction errors was estimated to be 0.2–1 €/MWh for penetration levels of 1–10 % of gross demand, assuming the Nordic balancing market was available (no bottlenecks) [27].

The use of an intra-day market to help reduce the imbalance costs of wind power has been examined in Germany [28] and in Finland [29] and Sweden [25] for the Nordic market. They have shown that for the current price assumptions and lower penetration levels there is not a straightforward benefit to use an intra-day market. This is because trading at an intra-day market would mean correcting all potential imbalances due to wind power forecast errors separately, whereas the imbalance payments only apply to the imbalances that affect the power system net imbalances. As wind imbalances are not 100 % of the time to the same direction (up or down) as system net imbalances (at low wind penetrations only 50 % of the time), this results in less payments.

4.2 Storage

The value of storage in the power system operation in UK was estimated to be 252–970 £/kW [7]. For Germany a 27 M€/year revenue could be foreseen for 400 MW CAES (250 M€ investment) [28]. In the NL, international exchange was seen as a more promising alternative to storage in the system [21]. In Ireland, adding storage did not bring additional value in the All Island Grid Study results [22].

For wind penetration levels of 10–20 % of gross demand in power systems, the cost effectiveness of building new electricity storage is still low (excluding hydro power with large reservoirs and some pumped hydro). With higher wind penetration levels the extra flexibility that also storages can provide will be beneficial for the power system operation, provided they are economically competitive with other forms of flexibility. It is important to notice, however, that any storage should be operated according to the needs of aggregated system balancing. It is not cost effective to provide dedicated back-up for wind power in large power systems where the variability of all loads and generators is effectively reduced by aggregating, in the same way as it is not effective to have dedicated storage for outages in a certain thermal power plant, or having specific plants following the variation of a certain load.

5 Transmission planning and costs

With current technology, new wind power plants are able to meet system operator expectations such as riding through voltage dips, supplying reactive power to the system, controlling terminal voltage, and participating in system operation with output and ramp rate control. Grid reinforcement may be needed for handling larger power flows and maintaining a stable and adequate voltage profile, and is commonly needed if new generation is installed in weak or congested grids far from load centres, or where no grid exists, such as offshore.

Transmission cost is the extra cost in the transmission system when wind power is integrated. Either all extra costs are allocated to wind power, or only part of the extra costs are allocated to wind power – grid reinforcements and new transmission lines often benefit also other consumers or producers and can be used for many purposes, such as increase of reliability and/or increased trading. The cost of grid reinforcements due to wind power is therefore very dependent on where the wind power plants are located relative to load and on the grid infrastructure, and one must expect numbers to vary from country to country. Grid reinforcement costs are by nature dependent on the existing grid. The costs vary with time and are dependent on when the generator is connected. After building some lines, often several generators can be connected before new reinforcement needs occur. After a certain time, new lines, substations or something else is needed. The grid reinforcement costs are not continuous; there can be single very high cost reinforcements. Using higher voltages generally results in lower costs per MW transported but this also means that there are even higher increments of capacity and grid costs. The same wind power plant, connected at different times, may therefore lead to different grid reinforcement costs. For transmission planning, the most cost effective solution in cases that require considerable grid reinforcements would be to build the transmission network for the final planned amount of wind power in the network – instead of having to upgrade transmission lines in several phases.

The reported results in the national case studies for grid reinforcements presented in Fig 6 are: UK [14]; Netherlands:[30]; Portugal : lower cost allocating only the proportion related to the wind program of total cost of each grid development or reinforcement [1]; Germany [8]; Ireland [22]; Denmark: [32] (allocating about 40 % of total grid reinforcement cost to wind power) and [33] for 2250 MW of additional off-shore wind power in 2025, excluding the costs of getting the offshore production on shore and no additional network reinforcement costs for increasing onshore wind power with 700 MW from 2007 to 2025.




Fig. 6. Comparison of the estimated costs for grid reinforcement costs due to wind power. For Denmark, the cost of increasing wind penetration from 20 % to 50 % is allocated to added wind power. For Ireland the range comes from allocating the cost for all renewables from 0 % penetration and for allocating the cost for added renewables (from 2.25 GW to 6.6 GW).

The grid reinforcement costs from studies in this report vary from 0 €/kW to 270 €/kW. In the US, a recent study reviewed a sample of 40 detailed transmission studies from 2001–2008 that have included wind power [34]. The range of transmission costs for wind investigated in these studies ranged from \$0/kW to over \$1500/kW. The majority of studies, however, have a unit cost of transmission that is below \$500/kW, and a median cost of \$300/kW. One interesting finding in the US is that unit transmission costs of wind do not appear to increase significantly with higher levels of wind penetration. Economies of scale appear to come into play when accessing large resource areas.

It is also important to note that grid reinforcements should be held up against the option of controlling wind output or altering operation of other generation in cases where grid adequacy is insufficient during only part of the time or for only some production and load situations.

The results from UK [35] suggest that at higher penetration levels, requiring sufficient fault ride through capability for large wind power plants is economically efficient compared with modifying the power system operation for ensuring power system security in case wind farms do not have fault ride through capability. In stability studies of the Iberian peninsula it is shown that to reach penetration levels of more than 10 %, fault ride through capability is required in the majority of wind power plants. Also the German studies conclude that a passive fault ride through capability will not be sufficient in the future. In addition, the turbines have to be able to provide reactive power to the grid. In a US study it was found that wind power plants with some dynamic reactive capability may reduce or eliminate the need for dynamic reactive devices on the transmission system [36].

Dynamic line ratings, taking into account the cooling effect of wind together with temperature in determining the transmission constraints, can increase transmission capacity from the North to the middle of Germany by 40 to 90 % at times when the German wind power generation is above 75 % of the installed capacity. In 99 % of the time the increase is above 15 % for all lines, except some very unfavourable cases, where only an increase of 5 % is calculated [37].

A Norwegian study shows that the power smoothing effect of geographically dispersed wind power plants gives a significant reduction of discarded wind energy in constrained networks, compared to a single up-scaled wind power plant site [38]. Studies in Norway [40], [45] and Sweden [39], show that coordination of hydro and wind generation in a region with limited export capability can reduce the need for grid upgrades. These studies also show that with comparatively high costs for grid reinforcements, it can be economically preferable to spill some few percentages of the annual wind or hydro generation as an alternative to increase

the transmission capability. Generally, a power system without any grid bottlenecks can be said to have excess grid capacity, hence not economic. Severe grid bottlenecks should of course be avoided.

6 Capacity value of wind power

Wind generation will also provide some additional load carrying capability to meet forecasted increases in system demand or power plant decommissioning. The analyses for system generation adequacy are made several weeks, months or years ahead and associated with static conditions of the system. This can be studied by a chronological generation-load model, that can include transmission and distribution capacities and constraints, or by probabilistic methods. The data required to make the required generation estimation includes the system demand and the availability data of generation units. There are several approaches used in the literature. Calculating the effective load carrying capability (ELCC) by determining the Loss-of-Load-Probability (LOLP) of the power system for different load levels is the most rigorous methodology available. Although the use of alternative, simplified methods appears to be somewhat popular, many of these have not been compared to the more robust approaches based on reliability analysis. We strongly encourage this comparison so that the trade-offs of using simplified approaches are transparent.

The results presented in Fig. 7 for capacity value of wind power are from: Germany [8]; Ireland [41]; Norway [40]; UK [14]; US Minnesota [9],[16]; US New York [23]; US California [17].

The capacity value of wind power has been estimated to be up to 40 % of installed wind power capacity if wind power production is strongly correlated with times of high load, and down to 5 % in higher penetration scenarios or if local wind characteristics correlate negatively with the system load profile. Aggregating larger areas benefits the capacity credit of wind power [42].




Fig. 7. Capacity credit of wind power, results from eight studies. The Ireland estimates were made for two power system configurations, with 5 GW and 6.5 GW peak load.

Results for the capacity credit of wind power in Fig. 7 show a considerable spread. One reason for different resulting levels arises from the wind regime at the wind power plant sites and the dimensioning of wind turbines. This is one explanation for low German capacity credit results shown in Fig. 7. For near zero penetration level, all capacity credit values are in the range of the capacity factor of the evaluated wind power plant installations. The positive correlation of wind and load is very beneficial, as can be seen in the case of US New York offshore capacity credit being 40 %.

An important issue is whether wind power owners will be paid for the capacity value or not. This is also an issue for other types of power plants and depends on the market regulation. Some reports use the term “capacity cost”. The definition of this term is the cost for compensating the difference in capacity value for wind power and capacity value for a conventional power plant. This “capacity cost” is not now in widespread use, but it is important to note that when it is calculated this compensation should be added in cheaper power plants (like OCGT). This is because the capacity credit is normally calculated for a system where there is danger for capacity deficit only during a time period in the range of hours per year or less. If the capacity credit is not high enough then it is necessary to install extra capacity, but then this extra capacity is only used for a limited number of hours per year. With this level of utilization, open cycle gas turbines (OCGTs) are preferred. These units have comparatively low investment costs. An alternative is to use voluntary load reduction. Both these alternatives have comparatively low capacity costs [43].

7 Recommendations for wind integration studies

In wind integration studies, it is very important to take the variability of wind into account in the proper way. The variability will smooth out to some extent if there is geospread wind power, and part of the variability can be forecast. Because of spatial variations of wind from turbine to turbine in a wind power plant – and to a greater degree from wind power plant to wind power plant – a sudden loss of all wind power on a system simultaneously due to a loss of wind is not a credible event. A sudden loss of large amounts of wind power due to voltage dips in the grid can be prevented by requiring fault-ride-through from the turbines.

Recommendations for wind integration studies include:

- (i) capturing the smoothed out variability of wind power production time series for the geographic diversity assumed and utilizing wind forecasting best practice for the uncertainty of wind power production;
- (ii) examining wind variation in combination with load variations, coupled with actual historic utility load and load forecasts;
- (iii) capturing system characteristics and response through operational simulations and modeling;
- (iv) examining actual costs independent of tariff design structure and
- (v) comparing the costs and benefits of wind power.

In most cases the question is whether extra investments in power systems are economically profitable or not in the new system with a larger amount of wind power – not only stating that a certain amount of extra reserve capacity and/or new transmission lines etc are a prerequisite in order to build any wind power.

For high penetration levels of wind power, the optimisation of the integrated system should be explored. Modifications to system configuration and operation practices to accommodate high wind penetration may be required. Not all current system operation techniques are designed to correctly incorporate the characteristics of wind generation and surely were not developed with that objective in mind. Increasing power system flexibility through such means as transmission to neighbouring areas, generation flexibility, demand side management and optimal use of storage (e.g. pumping hydro or thermal) in combination with market aggregation and market or system operation closer to real time will impact the amount of wind that can be integrated cost effectively.

Regarding capacity value of wind power, the recommendations are:

- (i) The availability of high quality chronological synchronized data that captures the correlation with load data is of paramount importance and the robustness of the calculations is highly dependent on the volume of this data.
- (ii) Approximations should be avoided, and a full effective load carrying capability (ELCC) calculation is the preferred method. Great care and attention are needed when approximations are used. It is challenging to compare capacity credits derived in different studies if different definitions are used ([43],[44]).

(iii) In some reports the term “capacity cost” is used. The meaning of this is the cost for the difference between capacity credit for wind power and capacity credit for a conventional power plant. It is then important to consider the lowest realistic cost compensation in order not to overestimate this cost [43].

8 Summary and future work

Several issues that impact the amount of wind power that can be integrated in a power system have been identified. Aggregation benefits of large areas help in reducing the variability and forecast errors of wind power, as well as in pooling more cost effective balancing resources. An alternative to large balancing areas is to allow and promote intra-day and intra-hour trading within and between different balancing areas in order to obtain low-cost balancing services. System scheduling and operating electricity markets at less than day-ahead time scales help reduce the forecast errors of wind power that affect operating reserves. Transmission is the key to aggregation benefits, electricity markets and larger balancing areas.

Wind integration has mainly been studied up to wind penetration levels of 10–20 % of gross demand (up to 50 % of peak load), with some first efforts to study higher penetration levels of 40–50 % of gross demand ([19],[20] and [22]). What happens at larger penetration levels, where wind becomes a more dominant part of the power system, is still not completely clear. Studies will have to cover larger interconnected areas to take the cross border transmission into account properly [42]. The future power systems may also provide different options for flexibility from the demand side that do not exist today. Future integration studies should take into account the foreseen larger penetration of solar PV or ocean power, which may help smooth the variability of individual technologies. The use of hydro systems with large water reservoirs for storage is likely the most efficient way to balance generation and supply, and for power systems that are linked to such large hydro facilities, this may be a key for economic operation with large penetration of wind generation. This has been studied in IEA Wind Task 24 (http://www.ieawind.org/Annex_XXIV.shtml), and there are still several unresolved issues that should be addressed in future studies.

9 References

- [1] H. Holttinen, P. Meibom, A. Orths, F.van Hulle, B.Lange, M. O’Malley, J. Pierik, B. Ummels, J.O. Tande, A. Estanqueiro, M. Matos, E. Gomez, L. Söder, G. Strbac, A. Shakoor, J.Ricardo, J. C. Smith, M.Milligan, E. Ela. “Design and operation of power systems with large amounts of wind power” Final report, IEA WIND Task 25, Phase one 2006-2008. Espoo, VTT. 200 p. + app. 29 p. VTT Tiedotteita - Research Notes 2493. Available at <http://www.vtt.fi/inf/pdf/tiedotteet/2009/T2493.pdf>
- [2] Söder, L., Hofmann, L., Orths, A., Holttinen, H., Wan, Y.-H., Tuohy, A. 2007. Experience from wind integration in some high penetration. IEEE Transactions on Energy Conversion, vol. 22, 2, pp. 4–12.
- [3] H. Holttinen, M. Milligan, B. Kirby, T. Acker, V. Neimane, T. Molinski, 2008. “Using standard deviation as a measure of increased operational reserve requirement for wind power” Wind Engineering, vol. 32, 4, ss. 355 – 377.
- [4] H. Holttinen, 2004. “The impact of large scale wind power production on the Nordic electricity system” PhD dissertation. VTT Publications 554. Espoo, VTT Processes. 82 p. + app. 111 p. Available at: <http://www.vtt.fi/inf/pdf/publications/2004/P554.pdf>.
- [5] U.Axelsson, R.Murray and V.Neimane. “4000 MW wind power in Sweden – Impact on regulation and reserve requirements”. Elforsk Report 05:19, Stockholm, 2005. Available at: <http://www.elforsk.se>.
- [6] Ilex, UMIST, UCD and QUB. “Operating reserve requirements as wind power penetration increases in the Irish electricity system.” Sustainable Energy Ireland, 2004.

- [7] Strbac, G., Shakoor, A., Black, M., Pudjianto, D. & Bopp, T. 2007. Impact of wind generation on the operation and development of the UK electricity systems. *Electrical Power Systems Research*, Vol. 77, Issue 9. Elsevier. Pp. 1143–1238.
- [8] Dena, 2005. Planning of the grid integration of wind energy in Germany onshore and offshore up to the year 2020 (Dena Grid study). Deutsche Energie-Agentur Dena, March 2005. English summary and full German version available at: <http://www.dena.de/themen/thema-reg/projektarchiv/>.
- [9] EnerNex/WindLogics 2006. Minnesota Wind Integration Study Final Report. Vol I, prepared for Minnesota Public Utilities Commission, Nov. 2006. http://www.puc.state.mn.us/portal/groups/public/documents/pdf_files/000664.pdf
- [10] Porter et al., July 2007. Intermittency analysis Final report. July, 2007. Available at: <http://www.uwig.org/CEC-500-2007-081.pdf>.
- [11] Svenska Kraftnät. 2008. Large scale expansion of wind power – Consequences for the transmission grid and need of regulation power. Available at: http://www.svk.se/Global/01_Om_oss/Pdf/Rapporter/080601_Bilaga_vindkrafttrapport_2008.pdf (In Swedish.)
- [12] Meibom, P., Weber, C., Barth, R. & Brand, H. 2009. Operational costs induced by fluctuating wind power production in Germany and Scandinavia. *IET Renewable Energy Generation*, Volume 3, Issue 1, p. 75–83, March 2009.
- [13] Söder, L. and Holttinen, H. 2008. On methodology for modelling power system impact on power systems. *International Journal of Global Energy Issues*, Vol. 29, 1–2, pp. 181–198.
- [14] Ilex Energy, Strbac, G. 2002. Quantifying the system costs of additional renewables in 2020. DTI, 2002. Available at: http://www.dti.gov.uk/energy/develop/080scar_report_v2_0.pdf.
- [15] Zavadil, R. 2006. Wind Integration Study for Public Service Company of Colorado. May 22, 2006. Available at http://www.xcelenergy.com/XLWEB/CDA/0,3080,1-1-1_1875_15056_15473-13518-2_171_258-0,00.html.
- [16] EnerNex/WindLogics, 2004. Xcel North study (Minnesota Department of Commerce). Available at: <http://www.state.mn.us/cgi-bin/portal/mn/jsp/content.do?contentid=536904447&contenttype=EDITORIAL&hpage=true&agency=Commerce>.
- [17] Shiu, H., Milligan, M., Kirby & B. Jackson, K. 2006. California Renewables Portfolio Standard Renewable Generation Integration Cost Analysis. California Energy Commission, PIER Public Interest Energy Research Programme. Available at: http://www.energy.ca.gov/pier/final_project_reports/CEC-500-2006-064.html.
- [18] PacifiCorp, 2005. Integrated Resource Planning. Available at: <http://www.pacificorp.com/Navigation/Navigation23807.html>.
- [19] Energinet.dk: System Plan 2007. available at: www.energinet.dk
- [20] Eriksen, P.B.; Orths, A.: Challenges and Solutions of Increasing from 20 to 50 Percent of Wind Energy Coverage in the Danish Power System until 2025; Invited Keynote Paper; Proceedings of the 7th international Workshop on Large Scale Integration of Wind Power and on Transmission Networks for Offshore Wind Farms; 26-28 May 2008, Madrid, Spain.
- [21] Ummels, B. C. 2009. Power System Operation with Large-Scale Wind Power in Liberalised Environments. Ph.D. thesis, Delft University of Technology, the Netherlands. 192 p
- [22] All Island Grid Study. 2008. Available at: <http://www.dcenr.gov.ie/Energy/North-South+Cooperation+in+the+Energy+Sector/All+Island+Electricity+Grid+Study.htm>.
- [23] GE Energy, 2005. The Effects of Integrating Wind Power on Transmission System Planning, Reliability, and Operations. Report on Phase 2, Prepared for The New York State Energy Research and Development Authority, City, State, Mar. 2005. Available at: http://www.nyiso.com/public/services/planning/special_studies.jsp
- [24] Holttinen, H., Saarikivi, P., Repo, S., Ikäheimo, J. & Koreneff, G. 2006. Prediction Errors and Balancing Costs for Wind Power Production in Finland. Proceedings of 6th workshop on Offshore and Large Scale Integration of Wind Power, 25–26th October, 2006, Delft, Netherlands.
- [25] Neimane, V. & Carlsson, F. 2008. A massive introduction of wind power. Changed market conditions? Elforsk report 08:41. Available at: http://www.vindenergi.org/Vindforskrapporter/v_132.pdf.

- [26] Brandberg & Broman. 2007. Future trading with regulating power, Magnus Brandberg and Niclas Broman, Master's Thesis, Uppsala Universitet. An updated version, together with Nilsson, in Minerals & Energy - Raw Materials Report, Volume 23, Issue 1 March 2008, pp. 1–11.
- [27] Helander, A., Holttinen, H. & Paatero, J. 2009. Impact of wind power on the power system imbalances in Finland. Submitted to IET Renewable Power Generation journal.
- [28] FGE/FGH/ISET: Bewertung der Optimierungspotenziale zur Integration der Stromerzeugung aus Windenergie in das Übertragungsnetz. 2007. Available at: <http://www.erneuerbare-energien.de/inhalt/42024/4591/>.
- [29] Holttinen, H. & Koreneff, G. 2007. Imbalance costs of wind power for a hydro power producer in Finland. Proceedings. European Wind Energy Conference EWEC2007. Milan, Italy, 7–10 May, 2007. European Wind Energy Association, EWEA
- [30] Jansen, C. P. J. & de Groot R. A. C. T. 2003. Connect 6000 MW: Aansluiting van 6000 MW offshore windvermogen op het Nederlandse elektriciteitsnet. Deel 2: Net op land. Kema 40330050-TDC 03-37074B. Oktober 2003.
- [31] REN, 2008. Plano de Desenvolvimento e Investimento na Rede de Transporte 2009-2014 (2019). REN, Rede Eléctrica Nacional, Feb. 2008. pp243, available at <http://www.centrodeinformacao.ren.pt>.
- [32] Electricity Infrastructure Committee. 2008. Technical Report on the future expansion and undergrounding of the electricity transmission grid; published by the Electricity Infrastructure Committee, April 2008. Available at: <http://www.energinet.dk>
- [33] EA Energianalyse A/S: 50 percent wind in 2025 (In Danish), June 2007. Available at: <http://www.ea-energianalyse.dk/publications.html>.
- [34] Mills, A., Wiser, R. & Porter, K. 2009. The Cost of Transmission for Wind Energy: A Review of Transmission Planning Studies. LBNL-1471E. February 2009.
- [35] Strbac, G. & Bopp, T. 2007. Value of fault ride through capability for wind farms. Report to Ofgem (<http://www.sedg.ac.uk>), July 2004
- [36] Loutan et al., November 2007. Available at: <http://www.uwig.org/CAISOIntRenewablesNov2007.pdf>.
- [37] Lange, M. & Focken, U. 2008. Studie zur Abschätzung der Netzkapazität in Mitteldeutschland in Wetterlagen mit hoher Windeinspeisung. 2008. Available at: <http://www.erneuerbare-energien.de/inhalt/42006/20049/>.
- [38] Korpås, M., Tande J. O., Uhlen, K. & Gjengedal, T. 2006. Planning and operation of large wind farms in areas with limited power transfer capacity. European Wind Energy Conference (EWEC), Athens, Greece, 27 February – 2 March 2006.
- [39] Matevosyan, J. 2006. Wind power integration in power system with transmission bottlenecks. PhD study, KTH, Sweden. Available at: <http://www.diva-portal.org/kth/theses/abstract.xsql?dbid=4108>.
- [40] Tande, J. O., Korpås, M., 2006. Impact of large scale wind power on system adequacy in a regional hydro-based power system with weak interconnections. Proceedings of Nordic Wind Power Conference NWPC 2006, 22–23 May, 2006, Espoo, Finland.
- [41] ESBNG, ESB National Grid. 2004. Impact of wind power generation in Ireland on the operation of conventional plant and the economic implications. February 2004.
- [42] Van Hulle, F., Tande, J. O., Uhlen, K., Warland, L., Korpås, M., Meibom, P., Sørensen, P., Morthorst, P. E., Cutululis, N., Larsen, H., Woyte, A., Verheij, F., Kleinschmidt, C., Moldovan, N., Holttinen, H., Lemström, B., Uski-Joutsenvuo, S., Gardner, P., Purchala, K., Tiedemann, A. & Kreutzkamp, P. 2009. Final Report TradeWind. (Available at <http://www.trade-wind.eu>.)
- [43] Söder, L. & Amelin M., 2008. A review of different methodologies used for calculation of wind power capacity credit Power and Energy Society General Meeting – Conversion and Delivery of Electrical Energy in the 21st Century, 2008 IEEE 20–24 July 2008, pp. 1–5.

- [44] Amelin, M. 2008. Comparison of Capacity Credit Calculation Methods for Conventional Power Plants and Wind Power, accepted in December 2008 for publication in IEEE Transactions on Power Systems.
- [45] Tande J.O., K Uhlen (2004) Cost analysis case study of grid integration of larger wind farms, Wind engineering, volume 28, No3, 2004, pp 265-273.