Research Repository UCD

Title	Novel Branch Centrality Measures for Electrical Power Systems Considering Both Load-serving and Circulating Currents
Authors(s)	Cuffe, Paul, Keane, Andrew
Publication date	2020-10-01
Publication information	Cuffe, Paul, and Andrew Keane. "Novel Branch Centrality Measures for Electrical Power Systems Considering Both Load-Serving and Circulating Currents." IEEE, 2020.
Conference details	The 6th IEEE International Energy Conference (EnergyCon 2020), Gammarth, Tunisia (held online due to coronavirus outbreak), 28 September - 1 October 2020
Publisher	IEEE
Item record/more information	http://hdl.handle.net/10197/11724
Publisher's statement	© 2020 IEEE. Personal use of this material is permitted. Permission from IEEE must be obtained for all other uses, in any current or future media, including reprinting/republishing this material for advertising or promotional purposes, creating new collective works, for resale or redistribution to servers or lists, or reuse of any copyrighted component of this work in other works.
Publisher's version (DOI)	10.1109/ENERGYCon48941.2020.9236589

Downloaded 2023-04-07T10:52:29Z

The UCD community has made this article openly available. Please share how this access benefits you. Your story matters! (@ucd_oa)

© Some rights reserved. For more information

Novel Branch Centrality Measures for Electrical Power Systems Considering Both Load-serving and Circulating Currents

P. Cuffe, *Member, IEEE*, and A. Keane, *Senior Member, IEEE*

Abstract—Recent work on transmission usage charging has offered compelling new perspectives on how current flows in electrical power systems. One new insight is that a certain component of branch current flows solely to serve loads in the system, whereas another component arises because of voltage mismatches between generator buses. These circulating currents affect active power losses and branch congestion, and thus may be of renewed interest to system operators. This paper presents novel power system visualizations which better show the separate load-serving and circulating aspects of a network. A key insight that emerges is the dual role of the branches in a system: they carry both load serving and circulating currents, in heterogeneous proportions. This perspective permits new branch centrality metrics to be proposed, which separately gauge a branch's role in serving these distinct functions.

I. INTRODUCTION

The present work uses recent advances in power flow tracing to discuss some new perspectives on the structure of power systems. Early work in power flow tracing was motivated by market liberalization [1, 2] and was generally notional in character (e.g [3, 4]), tending to knowingly disregard the physics of power transmission. Among the earliest contributions to frame the flow tracing question in more physical terms was Conejo's Z_{bus} approach [5, 6]. This technique relies on taking the inverse of the Y_{bus} matrix, which is a very fundamental descriptor of a network's connectivity. Similarly, the present work relies on a reordering and partitioning of the Y_{bus} matrix, such that the connectivity between and among PV buses and PQ buses is quantified separately.

The equations central to this new understanding were first presented in [7], and have been applied since to various power system problems, notably by the prolific Thukuram, who has used them for, *inter alia*: voltage stability improvement [8-11]; congestion management [12]; transmission system usage charging [13, 14]; generator reactive power margin improvement [15]; siting power electronic devices [16, 17]; and generator expansion planning [18, 19]. Others have used the techniques for probabilistic voltage stability analysis [20]; power system reliability evaluation [21]; voltage stability monitoring with realistic load models [22]; improved load curtailment [23]; and voltage security monitoring [24]. Sikiru's work [25-27], using related matrix partitions and eigen

decomposition, elucidates a more fundamental understanding of the inherent structural characteristics of power systems, as does work in [28].

The work of Abdelkader et al. offers a deeper conceptual understanding of the matrix partitioning enforced in [7]. In a culmination [29] of earlier research [30, 31] a compelling new perspective on how current flows in electrical networks is articulated. In a rigorous way, it is demonstrated that a separable portion of branch currents are entirely a consequence of voltage mismatches between generator nodes, whereas the remaining component of branch current necessarily arises to serve loads. The direct relationship between these circulating currents, and the theoretical minimum loss dispatch for a power system, has latterly been established in [32]. This insight on the origins of active power losses has been applied in designing voltage control schemes for wind generators [33].

The present paper seeks to modestly extend the discussion of the new paradigm articulated in [29]. To this end, new power system centrality measures are proposed which separately gauge a branches' participation in each function, facilitating load-serving or circulation currents. Network visualizations are presented to make this separation more tangible.

These new metrics are related to other proposed measures of branch electrical centrality [34-36] which may be better suited to power system structural analysis than naïve topological measures [37, 38]. This work's new centrality metrics may open up new ways to approach such difficult problems as optimal transmission switching [39, 40], where removing a line from a system can relieve congestion and achieve substantial cost savings. Identifying such lines, however, is computationally demanding and poorly understood [41]. Likewise, identifying lines whose removal may trigger cascading failures is challenging, and simple branch centrality metrics are not always useful in this role [42].

The matrix manipulations permitting the separation of branch currents are reviewed and presented in Section II, some novel visualizations and tutorial discussions of such current separations are given in Section III and conclusions are given in Section IV.

P. Cuffe (paul.cuffe@ucd.ie) and A. Keane are with the School of Electrical and Electronic Engineering, University College Dublin. This work has emanated from research conducted with the financial support of Science Foundation Ireland under the SFI Strategic Partnership Programme Grant Number SFI/15/SPP/E3125.

II. METHODOLOGY

A. Y_{bus} partitioning

The treatment begins by restating the Y_{bus} partitioning introduced by Kessel and Glavitsch in [7]. Starting with the Y_{bus} matrix, nodes are reordered such that generator buses (G index) and load buses (L) are grouped together. In block matrix form, this gives:

$$\begin{bmatrix} I_G \\ I_L \end{bmatrix} = \begin{bmatrix} Y_{GG} & Y_{GL} \\ Y_{LG} & Y_{LL} \end{bmatrix} \begin{bmatrix} V_G \\ V_L \end{bmatrix} \quad (1)$$

The motivation for this partitioning of the Y_{bus} matrix is to separately quantify the connectivity between and among generator and load buses. Symmetry in the Y_{bus} can be assumed in the absence of phase-shifting transformers [43], and so $Y_{LG}^T = Y_{GL}$. Note that this partitioning is particular to a specific set of online generators.

I_G and I_L are complex-valued vectors representing the nodal currents at generator and load buses, respectively, while V_G and V_L are corresponding complex nodal voltages. From (1):

$$I_G = Y_{GG}V_G + Y_{GL}V_L \quad (2)$$

$$I_L = Y_{LG}V_G + Y_{LL}V_L \quad (3)$$

Rearrange (3) to find that:

$$V_L = Z_{LL}I_L - Z_{LL}Y_{LG}V_G \quad (4)$$

Where $Z_{LL} = Y_{LL}^{-1}$. Substituting for V_L in (2):

$$I_G = (Y_{GG} - Y_{GL}Z_{LL}Y_{LG})V_G + Y_{GL}Z_{LL}I_L \quad (5)$$

Inspecting (4) and (5) indicates that they can be efficiently represented in matrix form:

$$\begin{bmatrix} V_L \\ I_G \end{bmatrix} = \begin{bmatrix} Z_{LL} & F_{LG} \\ K_{GL} & Y_{GGM} \end{bmatrix} \begin{bmatrix} I_L \\ V_G \end{bmatrix} \quad (6)$$

Where:

$$Y_{GGM} = Y_{GG} - Y_{GL}Z_{LL}Y_{LG} \quad (7)$$

$$F_{LG} = -Z_{LL}Y_{LG} = K_{GL}^T \quad (8)$$

B. Tracing current flows

According to the conceptual framework proposed in [29], voltage mismatches between generators in a power system cause circulating currents, I_G^{Circ} , which flow in addition to the load-serving currents in the system, I_L^{Load} . The authors of [29] show how these circulating currents components can be separately traced through the power system. Equations (9) to (13) are reproduced below from [29], and represent the central contributions of that work.

Each generator's circulating current I_G^{Circ} is given by:

$$I_G^{Circ} = Y_{GGM}V_G \quad (9)$$

The portion of this current component that flows in each branch (BR) is given by the M_{BR}^G matrix as follows:

$$I_{BR}^{Circ} = M_{BR}^G I_G^{Circ} \quad (10)$$

Where M_{BR}^G is calculated as:

$$M_{BR}^G = Y_{BR}A^T \begin{bmatrix} Z_{GGM} \\ -Z_{LL}Y_{LG}Z_{GGM} \end{bmatrix} \quad (11)$$

Noting that $Z_{GGM} = Y_{GGM}^{-1}$, Y_{BR} is the branch admittance matrix, and A is the system incidence matrix.

Similarly, the M_{BR}^L matrix describes the portion of each load node's (L) current demand that flows in each branch:

$$I_{BR}^{Load} = M_{BR}^L I_L \quad (12)$$

With:

$$M_{BR}^L = Y_{BR}A_L^T Z_{LL} \quad (13)$$

Where A_L is the incidence matrix partitioned to show just the connectivity of the load buses.

C. Novel centrality measures

One can readily define two novel branch centrality metrics by simply summing the rows of the M matrices, taking the absolute value of each element, denoted by the $|\cdot|$ superscript:

$$C_{BR}^{Circ} = \sum_G M_{BR}^{G|\cdot|} \quad (14)$$

And:

$$C_{BR}^{Load} = \sum_L M_{BR}^{L|\cdot|} \quad (15)$$

The motivation for the new centrality definitions in (14) and (15) is to separately quantify each branch's structural role in the power system; does a particular branch tend to redistribute circulating current between generators, or does it tend to deliver load-serving currents, or does it perform both roles? The present work conjectures that, for instance, these new centrality measures can offer insights into which branches cause congestion that affects particular market outcomes. A branch with a higher centrality of C^{Circ} could be expected to have a loading that varies a lot with particular dispatch conditions, whereas a branch with low C^{Circ} centrality could be anticipated to fluctuate less.

III. RESULTS

A. Test platform

The matrix calculations were implemented in MATLAB, with Cytoscape [44] providing network visualization functions. A notional 19 bus network, case19, is used to show the various matrices on a small network, and the centrality measures are portrayed for the larger and well-known IEEE test network, case118 [45]. These systems and raw results are available online in a persistent archival repository at [46].

Fig. 1 Visualizations of the M_{BR}^L and M_{BR}^G matrices for the *case19* network. The load participation factors are shown in **blue** in the top left panel, and the remaining panels show in **pink** each branch's participation in a particular generator's circulating current transactions.

TABLE I
CASE19 GENERATOR DISPATCH

	G1	G2	G3	G4	G5
Optimal Dispatch (MW)	64.7	88.9	67.8	93.6	87.5
Dispatch in Fig. 2 (MW)	44.7	88.9	87.8	93.6	87.5

B. Visualizing the M^L and M^G matrices

The separation of branch currents into load and generator induced components via Abdelkader's methods [29-31] offers an interesting new perspective on power flows in electrical networks. To make this separation tangible, the M_{BR}^L and M_{BR}^G matrices of the *case19* system are represented graphically in Fig 1. The (a) panel shows the absolute value of the M_{BR}^L matrix multiplied by the prevailing **load** demands, as in (12). These participation factors remain static for a given load level. Note the differing thickness of the load current participation at each generator's radial feed in (a): this indicates how the system's natural, loss-minimizing load-serving pathways require

differing current injections at each generation site [32].

By contrast, panels (b) to (f) are more dynamic, showing which branches carry each generator's **circulating current** for a particular dispatch condition. A generator's circulating current contribution is proportional to its deviation from its optimal dispatch level. As such, Fig. 1 maps which branches can become congested due to the chosen dispatch levels for certain generators. As may be anticipated, these effects are most pronounced in the vicinity of the particular generator. These diagrams show the zone of influence for each generator, by explicitly identifying the set of branches a generator's dispatch can affect.

In Fig. 1 each branch is plotted with a thickness proportional to the absolute value of its corresponding entry in the M matrix. A scaling can be inferred by noting that the generators connect on a radial feed, and these branches have a near-unity M_{BR}^G participation, as, logically, they carry the full quantity of circulating current their generator exchanges.

Fig. 2 The real component of the separate current components for the small case19 test network in the dispatch of Table I. Note the transaction of **circulating current** between G3, which is here operating above its optimal level, to G1, which is below its ideal.

Fig. 3 The case118 network, with branch thickness showing C^{Circ} (left) and C^{Load} (right).

C. Visualizing separable current components

As had been noted by previous authors [14], the K_{GL} matrix can be used to analytically determine an ideal loss-minimizing dispatch profile for generators [32]. This dispatch level, equal to the matrix product $K_{GL}L$, shows the ideal way that load-serving currents would flow through a system. When a generator's actual dispatch deviates from this theoretical optimal, this difference manifests as circulating current.

To make this idea concrete, in the specific conditions visualized in Fig. 2, G2, G4 and G5 are all producing their optimal level of active power, which manifests solely as load serving current, whereas G3 operates 20 MW above its optimal

level, and so it circulates current to G1, which is 20 MW below (see Table I, and compare also Fig. 1 (a), where the thickness of load serving currents from each generator corresponds to the optimal dispatch level) The **circulating current** transaction between these generators is depicted alongside the **load serving currents** in Fig. 2 (arrow thickness denotes the magnitude of the real component) It is clear that some branches carry only circulating current ($L6 \rightarrow L12$, $L10 \rightarrow L11$), others just load serving current ($L17 \rightarrow L19$), with most carrying varying portions of each. The circulating current transaction shown in Fig. 2 can be considered as the combined effect of the circulating current participations shown in Fig. 1 (b) and (f),

weighted by each generator's specific circulating contribution.

D. Visualizing C^{Circ} and C^{Load} centrality

The preceding discussion shows that branches in a power system may have varying importance in the load-serving and circulating current aspects of a network. To make this distinction concrete, Fig. 3 depicts both the C^{Circ} and C^{Load} centrality measures for each branch in the case118 network [45]. While Fig. 2 shows the actual separate current flows for particular dispatch conditions on the case19 network, the C^{Circ} and C^{Load} measures gauge the *generalized likelihood* that a branch will carry a certain class of current. Fig. 3 uses a force-directed layout to show that the case118 system has a distinct centrality structure with respect to the load-serving and circulating dimensions of the network. A branch may appear important for load current, or for redistributing circulating generator currents, or for both. These separate centralities indicate distinct functional roles which may be useful in identifying which branches contribute to congestion, or in analyzing a system's robustness against cascading failure, however this is left for future work.

IV. CONCLUSIONS

This work has sought to extend the discussion around the separability of load-serving and circulating currents in power systems. For instance, this approach, which does not require iterative load flow calculations, allows the direct identification of the set of branches whose loading is affected by a particular generator's dispatch level. Furthermore, the loading of these branches can be explicitly linked to how much each generator's actual dispatch deviates from its analytically calculated optimal value. Centrality measures were proposed to gauge each branches participation in each functional dimension of the network. Future work will assess the insightfulness of these centrality measures for specific power engineering problems.

ACKNOWLEDGEMENT

The authors gratefully acknowledge an insightful discussion with Dr. Sobhy Abdelkader in the conception stage of this work.

V. REFERENCES

- [1] A. J. Conejo, J. M. Arroyo, N. Alguacil, and A. L. Guijarro, "Transmission loss allocation: a comparison of different practical algorithms," *Power Systems, IEEE Transactions on*, vol. 17, no. 3, pp. 571-576, 2002, doi: 10.1109/tpwrs.2002.800894.
- [2] P. Jiuping, Y. Teklu, S. Rahman, and J. Koda, "Review of usage-based transmission cost allocation methods under open access," *Power Systems, IEEE Transactions on*, vol. 15, no. 4, pp. 1218-1224, 2000, doi: 10.1109/59.898093.
- [3] J. Bialek, "Tracing the flow of electricity," *IEE Proceedings-Generation, Transmission and Distribution*, vol. 143, no. 4, pp. 313-320, 1996.
- [4] D. Kirschen and G. Strbac, "Tracing active and reactive power between generators and loads using real and imaginary currents," *Power Systems, IEEE Transactions on*, vol. 14, no. 4, pp. 1312-1319, 1999, doi: 10.1109/59.801890.
- [5] A. J. Conejo, J. Contreras, D. A. Lima, and A. Padilha-Feltrin, "Zbus Transmission Network Cost Allocation," *Power Systems, IEEE Transactions on*, vol. 22, no. 1, pp. 342-349, 2007, doi: 10.1109/tpwrs.2006.889138.
- [6] A. J. Conejo, F. D. Galiana, and I. Kockar, "Z-bus loss allocation," *Power Systems, IEEE Transactions on*, vol. 16, no. 1, pp. 105-110, 2001, doi: 10.1109/59.910787.
- [7] P. Kessel and H. Glavitsch, "Estimating the Voltage Stability of a Power System," *Power Delivery, IEEE Transactions on*, vol. 1, no. 3, pp. 346-354, 1986, doi: 10.1109/tpwrd.1986.4308013.
- [8] B. D. Thukaram and K. Parthasarathy, "Optimal reactive power dispatch algorithm for voltage stability improvement," *International Journal of Electrical Power & Energy Systems*, vol. 18, no. 7, pp. 461-468, 1996, doi: http://dx.doi.org/10.1016/0142-0615(96)00004-X.
- [9] B. D. Thukaram and K. Parthasarathy, "An expert system for power system voltage stability improvement," *International Journal of Electrical Power & Energy Systems*, vol. 19, no. 6, pp. 385-392, 1997, doi: http://dx.doi.org/10.1016/S0142-0615(97)00007-0.
- [10] A. N. Udupa, D. Thukaram, and K. Parthasarathy, "An expert fuzzy control approach to voltage stability enhancement," *International Journal of Electrical Power & Energy Systems*, vol. 21, no. 4, pp. 279-287, 1999, doi: http://dx.doi.org/10.1016/S0142-0615(98)00049-0.
- [11] D. Thukaram, K. Parthasarathy, H. P. Khincha, N. Udupa, and A. Bansilal, "Voltage stability improvement: case studies of Indian power networks," *Electric Power Systems Research*, vol. 44, no. 1, pp. 35-44, 1998, doi: http://dx.doi.org/10.1016/S0378-7796(97)01208-X.
- [12] G. Yesuratnam and D. Thukaram, "Congestion management in open access based on relative electrical distances using voltage stability criteria," *Electric Power Systems Research*, vol. 77, no. 12, pp. 1608-1618, 2007, doi: http://dx.doi.org/10.1016/j.epsr.2006.11.007.
- [13] K. Visakha, D. Thukaram, and L. Jenkins, "Transmission charges of power contracts based on relative electrical distances in open access," *Electric Power Systems Research*, vol. 70, no. 2, pp. 153-161, 2004, doi: http://dx.doi.org/10.1016/j.epsr.2003.12.003.
- [14] D. Thukaram and C. Vyjayanthi, "Relative electrical distance concept for evaluation of network reactive power and loss contributions in a deregulated system," *Generation, Transmission & Distribution, IET*, vol. 3, no. 11, pp. 1000-1019, 2009, doi: 10.1049/iet-gtd.2009.0154.
- [15] C. Vyjayanthi and D. Thukaram, "Evaluation and improvement of generators reactive power margins in interconnected power systems," *Generation, Transmission & Distribution, IET*, vol. 5, no. 4, pp. 504-518, 2011, doi: 10.1049/iet-gtd.2010.0553.
- [16] D. Thukaram and A. Lomi, "Selection of static VAR compensator location and size for system voltage stability improvement," *Electric Power Systems Research*, vol. 54, no. 2, pp. 139-150, 2000, doi: http://dx.doi.org/10.1016/S0378-7796(99)00082-6.
- [17] D. Thukaram, L. Jenkins, and K. Visakha, "Improvement of system security with unified-power-flow controller at suitable locations under network contingencies of interconnected systems," *Generation, Transmission and Distribution, IEE Proceedings*, vol. 152, no. 5, pp. 682-690, 2005, doi: 10.1049/ip-gtd:20045235.
- [18] S. Surendra and D. Thukaram, "Identification of prospective locations for generation expansion with least augmentation of network," *Generation, Transmission & Distribution, IET*, vol. 7, no. 1, pp. 37-45, 2013, doi: 10.1049/iet-gtd.2012.0211.
- [19] D. Thukaram and C. Vyjayanthi, "Ranking of Prospective New Generation Location for a Power Network in a Deregulated System," in *Power System Technology and IEEE Power India Conference, 2008. POWERCON 2008. Joint International Conference on*, 12-15 Oct. 2008 2008, pp. 1-8, doi: 10.1109/icpst.2008.4745257.
- [20] S. Aboreshaid and R. Billinton, "Probabilistic evaluation of voltage stability," *Power Systems, IEEE Transactions on*, vol. 14, no. 1, pp. 342-348, 1999, doi: 10.1109/59.744553.
- [21] R. Billinton and S. Aboreshaid, "Voltage stability considerations in composite power system reliability evaluation," *Power Systems, IEEE Transactions on*, vol. 13, no. 2, pp. 655-660, 1998, doi: 10.1109/59.667396.
- [22] J. Hongjie, Y. Xiaodan, and Y. Yixin, "An improved voltage stability index and its application," *International Journal of Electrical Power & Energy Systems*, vol. 27, no. 8, pp. 567-574, 2005, doi: http://dx.doi.org/10.1016/j.ijepes.2005.08.012.
- [23] G. M. Huang and N. C. Nair, "Voltage stability constrained load curtailment procedure to evaluate power system reliability measures," in *Power Engineering Society Winter Meeting, 2002*.

- IEEE, 2002 2002, vol. 2, pp. 761-765 vol.2, doi: 10.1109/pesw.2002.985109.
- [24] I. K. Dassios, P. Cuffe, and A. Keane, "Visualizing voltage relationships using the unity row summation and real valued properties of the FLG matrix," *Electric Power Systems Research*, vol. 140, pp. 611-618, 2016.
- [25] T. H. Sikiru, A. A. Jimoh, Y. Hamam, J. T. Agee, and R. Ceschi, "Classification of networks based on inherent structural characteristics," in *Transmission and Distribution: Latin America Conference and Exposition (T&D-LA), 2012 Sixth IEEE/PES*, 3-5 Sept. 2012 2012, pp. 1-6, doi: 10.1109/tdc-la.2012.6319055.
- [26] T. H. Sikiru, A. A. Jimoh, and J. T. Agee, "Inherent structural characteristic indices of power system networks," *International Journal of Electrical Power & Energy Systems*, vol. 47, no. 0, pp. 218-224, 2013, doi: <http://dx.doi.org/10.1016/j.ijepes.2012.11.011>.
- [27] T. H. Sikiru, A. A. Jimoh, Y. Hamam, J. T. Agee, and R. Ceschi, "Voltage profile improvement based on network structural characteristics," in *6th IEEE transmission and distribution latin America conference, Montevideo, Uruguay*, 2012.
- [28] I. Dassios, A. Keane, and P. Cuffe, "Calculating nodal voltages using the admittance matrix spectrum of an electrical network," *Mathematics*, vol. 7, no. 1, p. 106, 2019.
- [29] S. M. Abdelkader, D. J. Morrow, and A. J. Conejo, "Network usage determination using a transformer analogy," *Generation, Transmission & Distribution, IET*, vol. 8, no. 1, pp. 81-90, 2014, doi: 10.1049/iet-gtd.2013.0134.
- [30] S. M. Abdelkader and D. Flynn, "A new method for transmission loss allocation considering the circulating currents between generators," *European Transactions on Electrical Power*, vol. 20, no. 8, pp. 1177-1189, 2010, doi: 10.1002/etep.395.
- [31] S. M. Abdelkader, "Characterization of Transmission Losses," *Power Systems, IEEE Transactions on*, vol. 26, no. 1, pp. 392-400, 2011, doi: 10.1109/tpwrs.2010.2052115.
- [32] P. Cuffe, I. Dassios, and A. Keane, "Analytic loss minimization: a proof," *IEEE Transactions on Power Systems*, vol. 31, no. 4, pp. 3322-3323, 2015.
- [33] P. Cuffe and L. F. Ochoa, "A Voltage Control Scheme for Generation-Dominated Networks to Maximize Power Export," *IEEE Transactions on Power Systems*, vol. 33, no. 6, pp. 7321-7323, 2018.
- [34] P. Hines and S. Blumsack, "A Centrality Measure for Electrical Networks," in *Hawaii International Conference on System Sciences, Proceedings of the 41st Annual*, 7-10 Jan. 2008 2008, pp. 185-185, doi: 10.1109/hicss.2008.5.
- [35] K. Wang, B.-h. Zhang, Z. Zhang, X.-g. Yin, and B. Wang, "An electrical betweenness approach for vulnerability assessment of power grids considering the capacity of generators and load," *Physica A: Statistical Mechanics and its Applications*, vol. 390, no. 23, pp. 4692-4701, 2011.
- [36] W. Zhifang, A. Scaglione, and R. J. Thomas, "Electrical centrality measures for electric power grid vulnerability analysis," in *Decision and Control (CDC), 2010 49th IEEE Conference on*, 15-17 Dec. 2010 2010, pp. 5792-5797, doi: 10.1109/cdc.2010.5717964.
- [37] P. Hines, E. Cotilla-Sanchez, and S. Blumsack, "Do topological models provide good information about electricity infrastructure vulnerability?," *Chaos: An Interdisciplinary Journal of Nonlinear Science*, vol. 20, no. 3, pp. -, 2010, doi: <http://dx.doi.org/10.1063/1.3489887>.
- [38] E. Cotilla-Sanchez, P. D. Hines, C. Barrows, and S. Blumsack, "Comparing the Topological and Electrical Structure of the North American Electric Power Infrastructure," *Systems Journal, IEEE*, vol. 6, no. 4, pp. 616-626, 2012, doi: 10.1109/jsyst.2012.2183033.
- [39] K. W. Hedman, S. S. Oren, and R. P. O'Neill, "A review of transmission switching and network topology optimization," in *Power and Energy Society General Meeting, 2011 IEEE*, 24-29 July 2011 2011, pp. 1-7, doi: 10.1109/pes.2011.6039857.
- [40] J. G. Rolim and L. J. B. Machado, "A study of the use of corrective switching in transmission systems," *Power Systems, IEEE Transactions on*, vol. 14, no. 1, pp. 336-341, 1999, doi: 10.1109/59.744552.
- [41] C. Barrows, S. Blumsack, and R. Bent, "Computationally efficient optimal Transmission Switching: Solution space reduction," in *Power and Energy Society General Meeting, 2012 IEEE*, 22-26 July 2012 2012, pp. 1-8, doi: 10.1109/pesgm.2012.6345550.
- [42] P. Cuffe, "A comparison of malicious interdiction strategies against electrical networks," *IEEE Journal on Emerging and Selected Topics in Circuits and Systems*, vol. 7, no. 2, pp. 205-217, 2017.
- [43] B. Stott, "Review of load-flow calculation methods," *Proceedings of the IEEE*, vol. 62, no. 7, pp. 916-929, 1974, doi: 10.1109/proc.1974.9544.
- [44] P. Shannon *et al.*, "Cytoscape: a software environment for integrated models of biomolecular interaction networks," *Genome research*, vol. 13, no. 11, pp. 2498-2504, 2003.
- [45] R. Christie, "Power System Test Case Archive" <http://www.ee.washington.edu/research/pstca/> (accessed).
- [46] P. Cuffe, "Raw data from "Novel Branch Centrality Measures for Electrical Power Systems Considering Both Load-serving and Circulating Currents".", <https://figshare.com/s/3058079c30ead6654b63>