Research Repository UCD

Title	A Probabilistic Modeling of Photo Voltaic Modules and Wind Power Generation Impact on Distribution Networks
Authors(s)	Soroudi, Alireza, Aien, Morteza, Ehsan, Mehdi
Publication date	2011-01
Publication information	Soroudi, Alireza, Morteza Aien, and Mehdi Ehsan. "A Probabilistic Modeling of Photo Voltaic Modules and Wind Power Generation Impact on Distribution Networks" 6, no. 2 (January, 2011).
Publisher	Institute of Electrical and Electronics Engineers
Item record/more information	http://hdl.handle.net/10197/6193
Publisher's statement	(c) 2011 IEEE. Personal use of this material is permitted. Permission from IEEE must be obtained for all other users, including reprinting/ republishing this material for advertising or promotional purposes, creating new collective works for resale or redistribution to servers or lists, or reuse of any copyrighted components of this work in other works
Publisher's version (DOI)	10.1109/JSYST.2011.2162994

Downloaded 2023-04-07T10:52:29Z

The UCD community has made this article openly available. Please share how this access benefits you. Your story matters! (@ucd_oa)

© Some rights reserved. For more information

A Probabilistic Modeling of Photo Voltaic Modules and Wind Power Generation Impact on Distribution Networks

Alireza Soroudi*, Morteza Aien, Mehdi Ehsan

Department of Electrical Engineering, Sharif University of Technology, Tehran, Iran

Abstract—The rapid growth in use of renewable intermittent energy resources (like wind turbines and solar panels) in distribution networks has increased the need for having an accurate and efficient method of handling the uncertainties associated to these technologies. In this paper, the unsymmetrical two point estimate method (US2PEM) is used to handle the uncertainties of renewable energy resources. The uncertainty of intermittent generation of wind turbine, photo voltaic cells and also electric loads, as input variables, are taken into account. The variation of active losses and imported power from the main grid are defined as output variables. The U2PEM is compared to Symmetrical two point estimate method (S2PEM), Gram Charlier and Latin Hypercube Sampling (LHS) where Monte Carlo Simulation (MCS) is used as a basis for comparison. The validity of the proposed method is examined by applying it on a standard radial 9-node distribution network and a realistic 574-node distribution network.

Index Terms—Monte Carlo simulation, PV cells, wind turbine, active losses, point estimate method.

I. INTRODUCTION

A. Motivation and problem description

The penetration level of Distributed generation (DG) units is increasing on power distribution networks across the world. In deregulated power systems, the Distribution Network Operators (DNOs) are responsible for maintaining the reliability and efficiency of distribution networks. They usually do this by performing investment in network components and applying some active loss reduction policies. The role of Distributed Generation (DG) units in decreasing the operating and investment costs is crucial. The DNOs need some tools to investigate the impact of DG units specially those intermittent ones like wind turbines and photo voltaic modules. The motivation of this study is to provide such a tool for DNOs in order to model the uncertainties of intermittent power generations of wind turbines, photo voltaic cells and also electric load values. It should not only reduce the computational burden but also maintain the accuracy of computation procedure.

B. Literature review

The benefits of DG units like active loss reduction [1], [2], reducing the energy costs in the short term [3], emission

reduction [4], distribution system service restoration [5], reliability improvement [6], [7] and incrementing the load balance factor of radial distribution networks [8] have been highly discussed in the literature. In recent years, the production of clean energy (renewable ones) by small power producers is encouraged [9]. The power produced by these technologies may be used in the market, in addition to being consumed locally [10]. The problem is that the generated power of renewable energy resources like wind turbines and photo voltaic cells are exposed to uncertainties. The probabilistic methods are widely used in power system operations and planning to deal with a variety of uncertainties [7]. The probabilistic power flow (PPF) is a tool which handles the uncertainties associated with input data of traditional power flow problem. A great deal of attention has been paid to the PPF problem in the literature. The PPF was first introduced in 1976 [11]. In [12], a convolution based technique was applied to consider the interdependent demands. In [13], a linearized set of load-flow equations were introduced to reduce the complexity of the problem. In [14], a combined Monte Carlo simulation technique and linearized power flow equations was employed. A Cumulant based method was proposed in [15] to deal with PPF problem. An enhancement to the traditional Cumulant method was implemented in [16], named Limit corrected Cumulant method (LCCM) which specifically addressed errors in the existing Cumulant method. This method produces multiple probability density functions (PDFs) and finds the final PDF combining the obtained PDFs. A hybrid Cumulant and Gram-Charlier expansion theory was introduced in [17] to reduce the computational time while maintaining a high degree of accuracy. In [18], an efficient Point Estimate Method (PEM) was proposed to handle the uncertainties of bus injections and line parameters. Four different versions of PEM were tried and tested in [19]. In [20], a Monte-Carlo simulation based method was applied to the nonlinear three-phase load flow equations of distribution networks including wind farms. A Latin Hypercube sampling (LHS) combined with Cholesky decomposition method (LHS-CD) was proposed in [21] or state space pruning [22] to reduce the computational burden of MCS. In [23], Cornish-Fisher expansion series were used to obtain the cumulative distribution function (CDF) of the output variables. In [24], a model based on 2PEM was used to take into account the correlated wind power resources and load values.

* Correspondence to: Alireza Soroudi, Department of Electrical Engineering, Sharif University of Technology, Tehran, Iran, e-mail: (alireza.soroudi@gmail.com).

C. Contributions

The contributions of this paper are two fold:

- 1) To reduce the computational burden while keeping the precision.
- 2) To analyze the impact of PV modules and wind turbines in the network, simultaneously.

D. Paper organization

The problem formulation is described in Section II. Section III presents the method used for modeling and dealing with uncertainties. The described model is applied on two distribution networks and the simulation results are presented and discussed in Section IV. Finally, conclusions are outlined in Section V.

II. PROBLEM FORMULATION

The assumptions used in problem formulation, constraints and the uncertainty modeling are explained as follows:

A. Constraints

1) *Power flow equations:* The power flow equations to be satisfied are:

$$\begin{aligned} P_i^{net} &= -P_i^D + P_i^{w/pv} \\ Q_i^{net} &= -Q_i^D + Q_i^{w/pv} \\ P_i^{net} &= V_i \sum_{j=1}^{N_b} Y_{ij} V_j \cos(\delta_i - \delta_j - \theta_{ij}) \\ Q_i^{net} &= V_i \sum_{j=1}^{N_b} Y_{ij} V_j \sin(\delta_i - \delta_j - \theta_{ij}) \end{aligned} \quad (1)$$

where P_i^{net}, Q_i^{net} are the net injected active and reactive power to bus i , respectively. The $P_i^{w/pv}, Q_i^{w/pv}$ are the active and reactive power of wind turbine/PV cells in bus i .

2) *Voltage limits:* The voltage magnitude of each bus, i.e. V_i should be kept between the operating limits, as follows:

$$V_{min} \leq V_i \leq V_{max} \quad (2)$$

where V_{min} and V_{max} are the minimum and maximum operating limits.

3) *Feeders and substation capacity limit:* To maintain the security of the feeders and substation, the flow of current/energy passing through them should be kept below the feeders/substation capacity limit as follows:

$$I_\ell \leq \bar{I}_\ell \quad (3)$$

where I_ℓ is the current passing through feeder ℓ and $\bar{I}_\ell$ is the maximum allowable current in feeder ℓ . For substation capacity constraint, the same philosophy holds, as follows:

$$S^{grid} \leq \bar{S}_{tr} \quad (4)$$

S^{grid} is the apparent power passing through substation transformer. The $\bar{S}_{tr}$ is the capacity of substation transformer.

B. Uncertainty modeling

In this study, the uncertain parameters are electric load in each bus and also the generated power of wind turbines and PV cell modules. The uncertainty modeling of each parameter is described as follows:

1) *Electric load modeling:* The electric load of each bus is modeled as a normal PDF:

$$PDF(S_i^D) = \frac{1}{\sqrt{(2\pi\sigma_i^D)}} \exp\left[-\frac{(S_i^D - \mu_i^D)^2}{2\sigma_i^D}\right] \quad (5)$$

where S_i^D is the apparent power demand in bus i and $\mu_i^D, (\sigma_i^D)^2$ are the mean and variance of demand in bus i , respectively.

2) *Wind Turbine generation pattern modeling:* The generated power of a wind turbine highly depends on the wind speed in the site. There are various methods to model wind behavior like time-series model [25], data mining algorithms [26] or clustering approach [27]. In this paper, the variation of wind speed, i.e. v , is modeled as a Weibull PDF and its characteristic function which relates the wind speed and the output of a wind turbine.

$$PDF(v) = \left(\frac{k}{c}\right)\left(\frac{v}{c}\right)^{k-1} \exp\left[-\left(\frac{v}{c}\right)^k\right] \quad (6)$$

where k and c are the shape and scale factor of the Weibull PDF of wind speed, respectively [28].

The generated power of the wind turbine is determined using its speed-power curve as follows:

$$P_i^w = \begin{cases} 0 & \text{if } v \leq v_{in}^c \text{ or } v \geq v_{out}^c \\ \frac{v - v_{in}^c}{v_{rated}^c - v_{in}^c} P_{i,r}^w & \text{if } v_{in}^c \leq v \leq v_{rated}^c \\ P_{i,r}^w & \text{else} \end{cases} \quad (7)$$

Where, $P_{i,r}^w$ is the rated power of wind turbine installed in bus i , P_i^w is the generated power of wind turbine in bus i , v_{out}^c is the cut-out speed, v_{in}^c is the cut-in speed and v_{rated} is the rated speed of the wind turbine. The speed-power curve of a typical wind turbine is depicted in Fig. 1.

Fig. 1. The idealized power curve of a wind turbine

3) *Photo voltaic cell generation pattern modeling* : The generated power of a photo voltaic module depends on three parameters namely, solar irradiance, ambient temperature of the site and finally the characteristics of the module itself. The solar irradiance is modeled using a Beta PDF described as follows:

$$PDF(s) = \begin{cases} \frac{\Gamma(\alpha+\beta)}{\Gamma(\alpha)\Gamma(\beta)} \times s^{\alpha-1} \times (1-s)^{\beta-1} & \text{if } 0 \leq s \leq 1, 0 \leq \alpha, \beta \\ 0 & \text{else} \end{cases} \quad (8)$$

where s is solar irradiance kW/m^2 ; α, β are parameters of the Beta probability distribution function;

$$\begin{aligned} P^{pv}(s) &= N \times FF \times V(s) \times I(s) \quad (9) \\ FF &= \frac{V_{MPP} \times I_{MPP}}{V_{oc} \times I_{sc}} \\ V(s) &= V_{oc} - K_v \times T_c \\ I(s) &= s_a \times [I_{sc} + K_i(T_c - 25)] \\ T_c &= T_A + s_a \times \frac{N_{OT} - 20}{0.8} \end{aligned}$$

where T_c is the cell temperature in $^\circ C$; T_A is the ambient temperature in $^\circ C$; K_v, K_i are voltage and current temperature coefficient $V/^\circ C, A/^\circ C$, respectively; N_{OT} is the nominal operating temperature of PV cell in $^\circ C$; FF is the fill factor; I_{sc} is the short circuit current in A ; V_{oc} is the open circuit voltage in V ; I_{MPP} and V_{MPP} are the current/voltage at maximum power point in A, V ; finally, s_a is the average solar irradiance [2].

C. Output variables

In this paper, two variables are of interest namely, Purchased active power from main grid, i.e. P^{grid} and active power losses, i.e. P^{loss} . The total active loss is calculated as follows:

$$P^{loss} = \sum_{i=1}^{N_b} P_i^{net} \quad (10)$$

where N_b is the number of all buses in the network.

III. UNCERTAINTY HANDLING METHOD

A. Monte Carlo method

The Monte Carlo method is a technique that uses random numbers and their probability density function to solve problems. This method is often used when the model is complex, nonlinear, or involves many uncertain parameters. A simulation can typically involve over 10000 evaluations of the model, a task which is computationally expensive. Monte Carlo method can be summarized as below:

- Step.1 Create a parametric model $Y = h(x_1, x_2, \dots, x_n)$
- Step.2 Generate a set of random inputs using their PDF
 $X^i = (x_1^i, x_2^i, \dots, x_n^i)$
- Step.3 Evaluate the model and calculate the Y^i
- Step.4 Repeat steps 2 and 3 for $i = 1$ to N

- Step.5 Analyze the results using histograms, summary statistics, confidence intervals and so on

The Monte Carlo method is usually used for validation of the proposed methods in the literature for solving the PPF.

B. Two point estimate method

- (8) The symmetrical two point estimate method (S2PEM), which has the symmetrical location of two sampling points, is described in the following steps [19]:

- Step.1 Determine the number of uncertain variables, n
- Step.2 Set $E(Y) = 0, E(Y^2) = 0$
- Step.3 Set $k = 1$
- Step.4 Determine the location of concentration points $\epsilon_{k,i}$ and their probabilities, i.e. $P_{k,i}$, as follows:

$$\epsilon_{k,i} = (-1)^{(i+1)} \sqrt{n} \quad (11)$$

$$P_{k,i} = \frac{1}{2n} \quad i=1,2 \quad (12)$$

- Step.5 Determine the concentration points $x_{k,i}$, as follows:

$$\begin{aligned} x_{k,i} &= \mu_{x_k} + \epsilon_{k,i} \times \sigma_{x_k} \quad (13) \\ i &= 1, 2 \end{aligned}$$

Where, μ_{x_k} and σ_{x_k} are the mean and standard deviation of x_k , respectively.

- Step.6 Run the deterministic power flow for both $x_{k,i}$, as follows:

$$\begin{aligned} X &= [x_1, x_2, \dots, x_{k,i}, \dots, x_n] \quad (14) \\ i &= 1, 2 \end{aligned}$$

- Step.7 Calculate $E(Y)$ and $E(Y^2)$ using:

$$E(Y) \cong \sum_{k=1}^n \sum_{i=1}^2 P_{k,i} h(x_1, x_2, \dots, x_{k,i}, \dots, x_n) \quad (15)$$

$$E(Y^2) \cong \sum_{k=1}^n \sum_{i=1}^2 P_{k,i} h^2(x_1, x_2, \dots, x_{k,i}, \dots, x_n)$$

- Step.8 Calculate the mean and standard deviation as follows:

$$\begin{aligned} \mu_Y &= E(Y) \quad (16) \\ \sigma_Y &= \sqrt{E(Y^2) - E^2(Y)} \end{aligned}$$

In unsymmetrical two point estimate method (US2PEM), the location of each sampling point is determined as follows:

$$\epsilon_{k,i} = \frac{\lambda_{k,3}}{2} + (-1)^{i+1} \sqrt{n + \frac{\lambda_{k,3}^2}{2}} \quad (17)$$

$$P_{k,i} = (-1)^i \frac{\epsilon_{k,3-i}}{n\zeta_k} \quad (18)$$

$$\zeta_k = 2\sqrt{n + \frac{\lambda_{k,3}^2}{2}}$$

$$\lambda_{k,3} = \frac{M_3(x_k)}{\sigma_{x_k}^3}$$

where $M_3(x_k), \lambda_{k,3}$ are the third moment and skewness of variable x_k , respectively.

IV. APPLICATION STUDY

Two case studies have been analyzed in this section: the first one is a radial 9-bus distribution network and the second one is a realistic 574-node distribution network. The results obtained by the S2PEM and US2PEM are compared with different methods namely, Monte Carlo, Latin Hypercube sampling (LHS) [21] and Gram Charlier method [17]. The technical characteristics of wind turbines and PV modules are described in Table.I and II, respectively [2]. The Weibull parameters of the wind speed in each wind farm for case-I are assumed to be $c = 8.78$, $k = 1.75$. The Beta parameters of solar radiation are assumed to be $\alpha = 6.38$, $\beta = 3.43$. In this study, for modeling the uncertainty of wind turbine, 10000 wind samples are generated using (6) then they are passed through speed-power curve of the wind turbine as depicted in Fig.1. The output of the wind turbine is shown in Fig.2 and used for representing the generated wind power.

Fig. 2. The histogram of wind speed and power out put of a 0.5 MW wind turbine

TABLE I
THE TECHNICAL CHARACTERISTICS OF WIND TURBINES

v_{in}^c (m/s)	v_{rated} (m/s)	v_{out}^c (m/s)	$P_{i,r}^w$ (MW)
3	13	25	0.5

TABLE II
THE TECHNICAL CHARACTERISTICS OF PV MODULES

I_{sc} (A)	V_{oc} (V)	I_{MPP} (A)	V_{MPP} (V)	K_v (mV/C°)	K_i (mA/C°)	N_{OT} (C°)
5.32	21.98	4.76	17.32	14.40	1.22	43

A. Case-I: A 9-bus test network

This case is a radial 9-bus distribution network and its single line diagram is presented in Fig.3 [4]. This network is assumed to have two wind turbines which their data have been given in Table III.

Fig. 3. The 9-bus distribution network of Case-I

TABLE III
THE INSTALLED DGs IN CASE-I

Bus	No of PV modules	No of WT
3	0	1
9	500	1

In Table III, the number of DG resources and their installation buses are specified. The results obtained for this case, include the mean and standard deviation values of active losses and imported power grid, absolute values of errors and also the running time as presented in Table IV.

The PDF of active power losses and imported power from the main grid are depicted in Fig.5 and Fig.4, respectively.

Fig. 4. Probability density function of imported power from main grid in Case-I

B. Case II: A realistic 574-bus urban French network

The second case is a 20-kV, 574-node distribution system, depicted in Fig.6, which is extracted from a real French urban network. This system has 573 sections with total length of 52.188 km, and 180 load points. This network is fed through one substation. These data have been extracted from reports of Electricité de France (EDF) [29] where more details can be found in [30].

The speed-power characteristics of the wind turbines in case II are the same as case I and In Table V, the number of DG resources and their installation bus are provided.

TABLE IV
COMPARISON OF RESULTS IN CASE-I (THE VALUES ARE IN MW)

Method		μ_{loss}	$err(\%)$	σ_{loss}	$err(\%)$	μ_{Pgrid}	$err(\%)$	σ_{Pgrid}	$err(\%)$	Time (s)
MCS		0.8764	0.0000	0.0205	0.0000	33.5080	0.0000	0.3705	0.0000	946.25
S2PEM		0.8415	3.9788	0.0211	3.1247	34.4988	2.9570	0.3841	3.6787	0.1400
LHS		0.8450	3.5809	0.0211	2.8122	34.3997	2.6613	0.3828	3.3108	143.3817
Gram Charlier	4th order	0.8482	3.2228	0.0210	2.5310	34.3106	2.3952	0.3815	2.9797	7.3361
	5th order	0.8510	2.9005	0.0200	2.2779	34.2303	2.1557	0.3606	2.6818	8.3152
	6th order	0.8993	2.6105	0.0209	2.0501	32.8579	1.9401	0.3616	2.4136	9.1634
	7th order	0.8558	2.3494	0.0209	1.8451	34.0931	1.7461	0.3625	2.1722	9.8642
US2PEM		0.8579	2.1145	0.0208	1.6606	32.9814	1.5715	0.3777	1.9550	0.1720

TABLE VI
COMPARISON OF RESULTS IN CASE-II (THE VALUES ARE IN MW)

Method		μ_{loss}	$err(\%)$	σ_{loss}	$err(\%)$	μ_{Pgrid}	$err(\%)$	σ_{Pgrid}	$err(\%)$	Time (s)
MCS		0.2565	0.0000	0.0811	0.0000	8.0918	0.0000	0.2483	0.0000	1264.3480
S2PEM		0.2691	4.9082	0.0840	3.5671	7.8688	-2.7559	0.2400	3.3413	16.4800
LHS		0.2470	3.7226	0.0791	2.4129	8.3047	2.6315	0.2561	3.1350	650.2130
Gram Charlier	4th order	0.2646	3.1578	0.0828	2.0959	7.8988	2.3852	0.2415	2.7285	79.6498
	5th order	0.2618	2.0469	0.0795	1.9356	8.2640	2.1279	0.2541	2.3284	81.3450
	6th order	0.2607	1.6454	0.0823	1.4744	8.2479	1.9292	0.2431	2.1105	83.8510
	7th order	0.2527	1.4714	0.0798	1.6296	7.9554	1.6852	0.2531	1.9205	90.1354
US2PEM		0.2591	1.0298	0.0822	1.2948	8.2106	1.4679	0.2525	1.6951	21.3450

Fig. 5. Probability density function of active losses in Case-I

TABLE V
THE INSTALLED DGs IN CASE-II

Bus	No of PV modules	No of WT
15	300	0
283	100	2
344	0	1
495	200	7
426	0	2
163	0	1

The results obtained for this case includes the mean and standard deviation values of active losses and imported power grid, absolute values of errors and also the running times have been all presented in Table VI. The PDF of imported power from main grid is depicted in Fig.7.

Fig. 6. Realistic 574-node distribution network

V. CONCLUSION

In this paper, the uncertainty handling of wind turbines, PV modules and electric load values is studied. Three different PDFs are used to describe the behaviors of aforementioned uncertainties. A Weibull, Beta and normal PDFs are chosen for modeling the uncertainties of wind speed, solar radiation and electric load, respectively. An unsymmetrical two point estimate method (U2PEM) is applied to handle the uncertainties of the mentioned variables. The Monte Carlo simulation is used for obtaining an accurate result as a basis for comparison. The simulation results showed that the values obtained by the

Fig. 7. Probability density function of imported power from main grid in Case-II

U2PEM are more accurate than other methods and also a great reduction in computational burden was observed.

REFERENCES

- [1] S.-H. Lee, J.-W. Park, Selection of optimal location and size of multiple distributed generations by using kalman filter algorithm, *IEEE Transactions on Power Systems*, 24 (3) (2009) 1393–1400.
- [2] Y. M. Atwa, E. F. El-Saadany, M. M. A. Salama, R. Seethapathy, Optimal renewable resources mix for distribution system energy loss minimization, *IEEE Transactions on Power Systems* 25 (1) (2010) 360–370.
- [3] A. Algarni, K. Bhattacharya, Disco operation considering dg units and their goodness factors, *IEEE Transactions on Power Systems*, 24 (4) (2009) 1831–1840.
- [4] A. Soroudi, M. Ehsan, H. Zareipour, A practical eco-environmental distribution network planning model including fuel cells and non-renewable distributed energy resources, *Renewable Energy* 36 (1) (2011) 179–188.
- [5] T. T. H. Pham, Y. Besanger, N. Hadjsaid, New challenges in power system restoration with large scale of dispersed generation insertion, *IEEE Transactions on Power Systems*, 24 (1) (2009) 398–406.
- [6] L. Wang, C. Singh, Reliability-constrained optimum placement of reclosers and distributed generators in distribution networks using an ant colony system algorithm, *Systems, Man, and Cybernetics, Part C: Applications and Reviews*, IEEE Transactions on 38 (6) (2008) 757–764.
- [7] L. Wang, C. Singh, Population-based intelligent search in reliability evaluation of generation systems with wind power penetration, *IEEE Transactions on Power Systems*, 23 (3) (2008) 1336–1345.
- [8] Y.-K. Wu, C.-Y. Lee, L.-C. Liu, S.-H. Tsai, Study of reconfiguration for the distribution system with distributed generators, *Power Delivery*, IEEE Transactions on 25 (3) (2010) 1678–1685.
- [9] S. Wong, K. Bhattacharya, J. Fuller, Long-term effects of feed-in tariffs and carbon taxes on distribution systems, *IEEE Transactions on Power Systems*, 25 (3) (2010) 1241–1253.
- [10] I. Maity, S. Rao, Simulation and pricing mechanism analysis of a solar-powered electrical microgrid, *Systems Journal*, IEEE 4 (3) (2010) 275–284.
- [11] B. Borkowska, Probabilistic load flow, *IEEE Transactions on Power Apparatus and Systems*, PAS-93 (3) (1974) 752–759.
- [12] R. Allan, C. Grigg, D. Newey, R. Simmons, Probabilistic power-flow techniques extended and applied to operational decision making, *Electrical Engineers, Proceedings of the Institution of* 123 (12) (1976) 1317–1324.
- [13] R. Allan, M. Al-Shakarchi, Probabilistic a.c. load flow, *Electrical Engineers, Proceedings of the Institution of* 123 (6) (1976) 531–536.
- [14] A. Leite da Silva, V. Arienti, Probabilistic load flow by a multilinear simulation algorithm, *Generation, Transmission and Distribution, IEE Proceedings C* 137 (4) (1990) 276–282.
- [15] A. Schellenberg, W. Rosehart, J. Aguado, Cumulant-based probabilistic optimal power flow (p-opf) with gaussian and gamma distributions, *IEEE Transactions on Power Systems*, 20 (2) (2005) 773–781.
- [16] A. Tamtum, A. Schellenberg, W. Rosehart, Enhancements to the cumulant method for probabilistic optimal power flow studies, *IEEE Transactions on Power Systems*, 24 (4) (2009) 1739–1746.
- [17] P. Zhang, S. Lee, Probabilistic load flow computation using the method of combined cumulants and gram-charlier expansion, *IEEE Transactions on Power Systems* 19 (1) (2004) 676–682.
- [18] C.-L. Su, Probabilistic load-flow computation using point estimate method, *IEEE Transactions on Power Systems*, 20 (4) (2005) 1843–1851.
- [19] J. Morales, J. Perez-Ruiz, Point estimate schemes to solve the probabilistic power flow, *IEEE Transactions on Power Systems*, 22 (4) (2007) 1594–1601.
- [20] P. Caramia, G. Carpinelli, M. Pagano, P. Varilone, Probabilistic three-phase load flow for unbalanced electrical distribution systems with wind farms, *Renewable Power Generation, IET* 1 (2) (2007) 115–122.
- [21] S. Wong, K. Bhattacharya, J. Fuller, Electric power distribution system design and planning in a deregulated environment, *Generation, Transmission Distribution, IET* 3 (12) (2009) 1061–1078.
- [22] R. C. Green, L. Wang, Z. Wang, M. Alam, C. Singh, Power system reliability assessment using intelligent state space pruning techniques: A comparative study, in: *Power System Technology (POWERCON)*, 2010 International Conference on, 2010, pp. 1–8.
- [23] J. Usaola, Probabilistic load flow in systems with wind generation, *Generation, Transmission Distribution, IET* 3 (12) (2009) 1031–1041.
- [24] J. Morales, L. Baringo, A. Conejo, R. Minguez, Probabilistic power flow with correlated wind sources, *Generation, Transmission Distribution, IET* 4 (5) (2010) 641–651.
- [25] A. Kusiak, Z. Zhang, Short-horizon prediction of wind power: A data-driven approach, *IEEE Transactions on Energy Conversion* 25 (4) (2010) 1112–1122.
- [26] A. Kusiak, W. Li, Virtual models for prediction of wind turbine parameters, *Energy Conversion, IEEE Transactions on* 25 (1) (2010) 245–252.
- [27] A. Kusiak, W. Li, Short-term prediction of wind power with a clustering approach, *Renewable Energy* 35 (10) (2010) 2362–2369.
- [28] A. Soroudi, M. Ehsan, A possibilistic-probabilistic tool for evaluating the impact of stochastic renewable and controllable power generation on energy losses in distribution networks—a case study, *Renewable and Sustainable Energy Reviews* 15 (1) (2011) 794–800.
- [29] Electricite de France (EDF), online: <http://www.edf.com>, accessed Dec 2010.
- [30] B. Berseneff, *Reglage de la tension dans les reseaux de distribution du futur/ volt var control in future distribution networks*, Ph.D. thesis, Grenoble, France (2010).

Alireza Soroudi Received his B. Sc and M. Sc degrees in electrical engineering in 2002 and 2003 respectively from Sharif University of Technology, Tehran, Iran. Presently, he is a Ph.D candidate at Sharif University of Technology. His research interests are power system planning and optimization methods.

Morteza Aien Received his B.Sc. degree in electrical engineering from the Birjand university, Iran, in 2009. He is now pursuing M.Sc. degree in electrical engineering from in Sharif University of Technology. His research interests include operation, planning and economics of power systems including renewable energies, as well as optimization theory.

Mehdi Ehsan Received his B.Sc and M.Sc in Electrical Engineering from Technical College of Tehran University in 1963, PhD and DIC from Imperial College University of London in 1976 since then, he has been with the Electrical Engineering Department of Sharif University of Technology. He is currently a professor. His research interests are power systems dynamics and stability, application of expert systems in power system operation.